




**MUNICIPAL CORPORATION OF DELHI
OFFICE OF DEPUTY HEALTH OFFICER
NAJAFGARH ZONE**



No: DHO/NGZ/MCD/2025/D- 1086

Dated- 26/8/2025

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - **MODERN CONVENT SCHOOL**
2. SCHOOL ADDRESS:- **Sec-4, Dwarka, New Delhi-110078.**
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: **BOYS- 2105 GIRLS – 1762 TOTAL = 3867**
5. NO. OF STAFFS: **MALE - 89 FEMALE – 179 TOTAL = 268**

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard

Note:- (B+G+ +04 upper floors)

**Deputy Health Officer
Najafgarh Zone
Municipal Corporation Of Delhi
Health Deptt., Najafgarh Zone**

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)

	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL LABORATORY, <u>WATER TREATMENT PLANT NANGLOI , DELHI-110041</u>	 2025 International Year of Cooperatives Cooperatives Build a Better World
---	---	---


Water Sample Analysis report of samples collected from "Modern Convent School ", Sector-4 Dwarka, New Delhi – 110078 vide Challan No. 40 Dt-04.05.2026.

S1:- DJB Water Supply at above site.

S2:- Drinking Point with (R.O.) at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY.						
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	04.05.2026	
2.	Date of Analysis	-----	--	--	06.05.2026	
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	3.0	1.0
6.	PH value	-----	6.5	8.5	7.40	7.0
7.	Electrical Conductivity	µmho/cm	--	--	301.0	179.3
8.	Total dissolved solids	mg/l	500	2000	195.6	116.5
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	80	64
11.	Total Hardness	mg/l	200	600	136	80
12.	Calcium Hardness	mg/l	--	--	80	46
13.	Magnesium Hardness	mg/l	--	--	56	34
14.	Calcium as Ca	mg/l	75	200	32	18.4
15.	Magnesium as Mg	mg/l	30	100	13.44	8.16
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	Nil	Nil
18.	Nitrate as No ₃	mg/l	45	N.R.	2.1	1.0
19.	Sulphate	mg/l	200	400	32	18
20.	Chloride	mg/l	250	1000	20	12
21.	Fluoride	mg/l	1	1.50	0.30	0.16
22.	Dissolve Iron	mg/l	1	N.R.	0.06	ND
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.60	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS:- As per the tested parameters Sample-S1 & S2 is found Satisfactory and can be used for drinking purpose.


ACWA
 Asstt. Chief Water Analyst
 DELHI JAL BOARD
 Govt. of N.C.T. Delhi
 Quality Control Laboratory
 Water Works Nangloi, Delhi-41


CHEMIST


A/BACT.